



FAIR Quality Institute

(Food Analysis & Industrial Research Quality Institute)

(Govt. Approved Lab)

TEST REPORT

ULR - TC558720000000344F

Issued to : M/s Jasan Travel Marketing Pvt. Ltd.

Bhabat Road, Near Peer Baba, Opposite Tennis Academy
Zirakpur, Mohali-140603

Report No. : FQI/20/06/08/001

Date of Issue : 20.06.2020

Mfg. by : N.S.

SAMPLE PARTICULARS

1. Nature of the sample	: Supply Water	7. Date of recd.	: 08.06.2020
2. Brand name, if any	: N.S.	8. Client ref. No.	: N.S.
3. Sampling Method	: Sample not drawn by us.	9. Sample pkg.	: In poly bottle
4. Batch No./Code No.	: N.S.	10. Sample qty.	: 1 Ltr. Approx.
5. Mfd./Pkd. Date	: N.S.	11. Best Before	: N.S.
6. Sample description	: Clear colourless liquid.		

TEST RESULTS

Test started on : 08.06.2020

Test completed on : 20.06.2020

Sl. No.	Parameter	Result	Unit	Specification/Requirement as per IS 10500:2012 Amd. 2018		Test Method
				Acceptable Limit	Permissible Limit, in absence of Alternate source	
Physical & Chemical Parameters						
1	Odour	Agreeable	-----	Agreeable	Agreeable	IS 3025 (Part-5):1983 (2017)
2	Taste	Agreeable	-----	Agreeable	Agreeable	IS 3025 (Part-7):1984 (2017)
3	pH value (at 25 ^o C)	7.25	-----	6.5 to 8.5	No Relaxation	IS 3025 (Part-11):1983 (2017)
4	Total Dissolved Solids	201	mg/l	500 Max.	2000 Max.	IS 3025 (Part-16):1984 (2017)
5	Calcium (as Ca)	9.70	mg/l	75 Max.	200 Max.	IS 3025 (Part-40):1991 (2014)
6	Chloride (as Cl)	15.35	mg/l	250 Max.	1000 Max.	IS 3025 (Part-32):1988 (2014)
7	Iron (as Fe)	N.D.(D. L. -0.1)	mg/l	1.0 Max.	No Relaxation	IS 3025 (Part-53):2003 (2014)
8	Magnesium (as Mg)	6.86	mg/l	30 Max.	100 Max.	APHA 3500-Mg B:2012
9	Total Alkalinity (as CaCO ₃)	11.29	mg/l	200 Max.	600 Max.	IS 3025 (Part-23):1986 (2014)
10	Total Hardness (as CaCO ₃)	52.42	mg/l	200 Max.	600 Max.	IS 3025 (Part-21):2009 (2014)

Note : 1. N.S. -Not Stated, N.D.-Not Detected, D.L.-Detection Limit

Vivek Pathak
(Authorized Signatory)

* The results listed refer only to the tested sample and applicable parameter.
 * This report, in full or in part, shall not be used for advertising or as evidence in any court of law.
 * This report can not be reproduced, except when in full, without the written permission of the C.E.O.
 * The sample will be destroyed after three weeks from the date of issue of the test report.
 * (in case of non-perishable products only)
 * The liability of the laboratory is limited to the invoiced amount.
 * All disputes are subjected to the Delhi Jurisdiction.



FSSAI Approved Lab

Agmark Approved Lab.

AN ISO 9001 : 2015 CERTIFIED LAB

Address : Plot No. 635, IInd Floor, Opp. Metro Pillar No. 512, Main Rohtak Road, Mundka Industrial Area, Mundka, New Delhi - 110041
Phone : +91-11-65554115 Mobile : +91-9818961567 Email : fqilab@gmail.com, fqilabs@gmail.com



FAIR Quality Institute

(Food Analysis & Industrial Research Quality Institute)

(Govt. Approved Lab)

TEST REPORT

ULR - TC55872000000345F

Issued to : M/s Jasan Travel Marketing Pvt. Ltd.

Bhabat Road, Near Peer Baba, Opposite Tennis Academy
Zirakpur, Mohali-140603

Report No. : FQI/20/06/08/002

Date of Issue : 20.06.2020

Mfg. by : N.S.

SAMPLE PARTICULARS

1. Nature of the sample	: R.O. Water	7. Date of recd.	: 08.06.2020
2. Brand name, if any	: N.S.	8. Client ref. No.	: N.S.
3. Sampling Method	: Sample not drawn by us.	9. Sample pkg.	: In poly bottle
4. Batch No./Code No.	: N.S.	10. Sample qnty.	: 1 Ltr. Approx.
5. Mfd./Pkd. Date	: N.S.	11. Best Before	: N.S.
6. Sample description	: Clear colourless liquid.		

TEST RESULTS

Test started on : 08.06.2020

Test completed on : 20.06.2020

Sl. No.	Parameter	Result	Unit	Specification/Requirement as per IS 10500:2012 Amd. 2018		Test Method
				Acceptable Limit	Permissible Limit, in absence of Alternate source	
Physical & Chemical Parameters						
1	Odour	Agreeable	----	Agreeable	Agreeable	IS 3025 (Part-5):1983 (2017)
2	Taste	Agreeable	----	Agreeable	Agreeable	IS 3025 (Part-7):1984 (2017)
3	pH value (at 25°C)	6.64	----	6.5 to 8.5	No Relaxation	IS 3025 (Part-11):1983 (2017)
4	Total Dissolved Solids	53	mg/l	500 Max.	2000 Max.	IS 3025 (Part-16):1984 (2017)
5	Calcium (as Ca)	2.42	mg/l	75 Max.	200 Max.	IS 3025 (Part-40):1991 (2014)
6	Chloride (as Cl)	8.04	mg/l	250 Max.	1000 Max.	IS 3025 (Part-32):1988 (2014)
7	Iron (as Fe)	N.D.(D. L. -0.1)	mg/l	1.0 Max.	No Relaxation	IS 3025 (Part-53):2003 (2014)
8	Magnesium (as Mg)	0.98	mg/l	30 Max.	100 Max.	APHA 3500-Mg B:2012
9	Total Alkalinity (as CaCO ₃)	6.16	mg/l	200 Max.	600 Max.	IS 3025 (Part-23):1986 (2014)
10	Total Hardness (as CaCO ₃)	10.08	mg/l	200 Max.	600 Max.	IS 3025 (Part-21):2009 (2014)

Note : 1. N.S. -Not Stated, N.D.-Not Detected, D.L.-Detection Limit


Vivek Pathak

(Authorized Signatory)

The results listed refer only to the tested sample and applicable parameter.
This report, in full or in part, shall not be used for advertising or as evidence in any court of law.
This report can not be reproduced, except when in full, without the written permission of the C.E.O.
The sample will be destroyed after three weeks from the date of issue of the test report.
(in case of non-perishable products only)
The liability of the laboratory is limited to the invoiced amount.
All disputes are subjected to the Delhi Jurisdiction.





FAIR Quality Institute

(Food Analysis & Industrial Research Quality Institute)

(Govt. Approved Lab)

TEST REPORT

ULR - TC558720000000346F

Issued to : M/s Jasan Travel Marketing Pvt. Ltd.
Bhabat Road, Near Peer Baba, Opposite Tennis Academy
Zirakpur, Mohali-140603

Report No. : FQI/20/06/08/003
Date of Issue : 20.06.2020

Mfg. by : N.S.

SAMPLE PARTICULARS

1. Nature of the sample	: R.O. Water + 2 capsules of Jasan J7	7. Date of recd.	: 08.06.2020
2. Brand name, if any	: N.S.	8. Client ref. No.	: N.S.
3. Sampling Method	: Sample not drawn by us.	9. Sample pkg.	: In poly bottle
4. Batch No./Code No.	: N.S.	10. Sample qty.	: 1 Ltr. Approx.
5. Mfd./Pkd. Date	: N.S.	11. Best Before	: N.S.
6. Sample description	: Clear colourless liquid.		

TEST RESULTS

Test started on : 08.06.2020

Test completed on : 20.06.2020

Sl. No.	Parameter	Result	Unit	Specification/Requirement as per IS 10500:2012 Amd. 2018		Test Method
				Acceptable Limit	Permissible Limit, in absence of Alternate source	
Physical & Chemical Parameters						
1	Odour	Agreeable	-----	Agreeable	Agreeable	IS 3025 (Part-5):1983 (2017)
2	Taste	Agreeable	-----	Agreeable	Agreeable	IS 3025 (Part-7):1984 (2017)
3	pH value (at 25°C)	7.11	-----	6.5 to 8.5	No Relaxation	IS 3025 (Part-11):1983 (2017)
4	Total Dissolved Solids	476	mg/l	500 Max.	2000 Max.	IS 3025 (Part-16):1984 (2017)
5	Calcium (as Ca)	61.41	mg/l	75 Max.	200 Max.	IS 3025 (Part-40):1991 (2014)
6	Chloride (as Cl)	20.47	mg/l	250 Max.	1000 Max.	IS 3025 (Part-32):1988 (2014)
7	Iron (as Fe)	0.74	mg/l	1.0 Max.	No Relaxation	IS 3025 (Part-53):2003 (2014)
8	Magnesium (as Mg)	8.82	mg/l	30 Max.	100 Max.	APHA 3500-Mg B:2012
9	Total Alkalinity (as CaCO ₃)	10.26	mg/l	200 Max.	600 Max.	IS 3025 (Part-23):1986 (2014)
10	Total Hardness (as CaCO ₃)	189.50	mg/l	200 Max.	600 Max.	IS 3025 (Part-21):2009 (2014)

Note : 1. N.S. -Not Stated


Vivek Pathak

(Authorized Signatory)

* The results listed refer only to the tested sample and applicable parameter.
* This report, in full or in part, shall not be used for advertising or as evidence in any court of law.
* This report can not be reproduced, except when in full, without the written permission of the C.E.O.
* The sample will be destroyed after three weeks from the date of issue of the test report.
(in case of non-perishable products only)
* The liability of the laboratory is limited to the invoiced amount.
* All disputes are subjected to the Delhi Jurisdiction.



■ FSSAI Approved Lab

■ Agmark Approved Lab.

■ AN ISO 9001:2015 CERTIFIED LAB

Address : Plot No. 635, IInd Floor, Opp. Metro Pillar No. 512, Main Rohtak Road, Mundka Industrial Area, Mundka, New Delhi - 110041
Phone : +91-11-65554115 Mobile : +91-9818961567 Email : fqilab@gmail.com, fqilabs@gmail.com